

Table of accuracy class A

Size of metre measurement (mm.)	Minimum flow rate			Range of maximum flow rate					
	Minimum flow rate (cubic metre/hour)	Tested volume (V)	Maximum permissible error	Range of flow rate (cubic metre/hour)	Tested volume (V)	Maximum permissible error	Specified flow rate (cubic metre/hour)	Tested volume (V)	Maximum permissible error
15	0.06	5	0.05V	0.15	10	0.02V	1.5	100	0.02V
20	0.1	5	0.05V	0.25	10	0.02V	2.5	100	0.02V
25	0.14	5	0.05V	0.35	10	0.02V	3.5	100	0.02V
32	0.24	10	0.05V	0.6	20	0.02V	6	200	0.02V
40	0.4	20	0.05V	1	50	0.02V	10	500	0.02V
50	1.2	50	0.05V	4.5	200	0.02V	15	500	0.02V
65	2	50	0.05V	7.5	200	0.02V	25	1,000	0.02V
80	3.2	100	0.05V	12	500	0.02V	40	1,000	0.02V
100	4.8	200	0.05V	18	500	0.02V	60	2,000	0.02V
150	12	500	0.05V	45	2,000	0.02V	150	3,000	0.02V
200	20	500	0.05V	75	2,000	0.02V	250	5,000	0.02V
250	32	1,000	0.05V	120	3,000	0.02V	400	10,000	0.02V
300	48	2,000	0.05V	180	4,000	0.02V	600	15,000	0.02V
400	80	2,000	0.05V	300	10,000	0.02V	1,000	20,000	0.02V
500	120	3,000	0.05V	450	10,000	0.02V	1,500	25,000	0.02V